



OFFICIAL LISTING

NSF certifies that the products appearing on this Listing conform to the requirements of
NSF/ANSI/CAN 61 - Drinking Water System Components - Health Effects

This is the Official Listing recorded on June 8, 2022.

Cembrane A/S
Nøglegårdsvej 10
Lynge 3540
Denmark
45 2 148 4321

Facility: Lynge, Denmark

Mechanical Devices

Trade Designation	Size	Water Contact Temp	Water Contact Material
Filtration Devices/Components [1] [2] [3]			
SiC BLOX FX Series	N/A	D. HOT	MLTPL

[1] The SiC BLOX FX series stack is certified for a minimum daily permeate flow of 10,000 liters per day per module, up to ten (10) modules.

[2] The SiC BLOX FX series stack requires a 10.5 gallons per minute (gpm) flush per module up to ten (10) for five minutes with de-ionized water before use.

[3] The SiC BLOX FX series is certified for municipal treatment facilities end use.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF.

1 of 1